

	ITEM NO.	QTY.	PART NO.	DESCRIPTION	WEIGHT [ea.]	
	1	2	588-5020	TOP END 60' x 20'	310 [141]	
	2	5	588-5030	TOP MID, 60' x 20'	290 [132]	
	3	6	588-5040	CENTERPOLE	115 [52.2]	
	4	36	588-5060	SIDE POLE	12 [5.4]	
	5	36	588-5061	CROWN & NUT	2 [1]	
	6	44	588-5080	STAKE BAR	6 [2.8]	
	7	88	589-1401	STAKE, 1" x 42"	9 [4.1]	
	8	48	589-1403	STAKE, 3/4" x 36"	7 [3.2]	
	9	44	588-5080	GUY ASSEMBLY	2 [1]	
	10	6	588-5050	FLAG POLE	3 [1.4]	
	11	6	588-5051	FLAG	3 [1.4]	
	12	18	589-0620	WALL FR WINDOW, 8' x 20'	40 [18.1]	

ANCHORING:
- ALL SIDE POLE LOCATIONS ANCHORED WITH A SINGLE GUY STRAP AND 2- 1"x42" PINS.
- ALL SIDE POLES SHALL BE ANCHORED WITH 1- 3/4"x36" PIN
- ALL CENTER POLES SHALL BE ANCHORED WITH 2- 3/4"x36" PIN
- ALL CORNERS SHALL BE ANCHORED WITH 3 GUY STRAPS, 45" APART; EACH GUY STRAP
SHALL HAVE 2- 1"x42" PINS
- EACH GUY LOCATION SHALL HAVE A RESTRAINT CAPACITY OF 13.5KN [3,000 lbf] TO
WITHSTAND A 100kg/b [6.2 Mph] WIND
- EACH 1"x42" PIN SHALL REQUIRE A PULLOUT FORCE OF 13.5KN [3,000 lbf]
- EACH 3/4"x36" PIN SHALL REQUIRE A PULLOUT FORCE OF 9KN [2,000 lbf]

*INSTALLATION CREW MUST ENSURE THAT EACH STRUCTURE/INSTALLATION IS PROPERLY SECURED. SITE CONDITIONS MAY REQUIRE ALTERNATE ANCHORING METHODS OR ADDITIONAL ANCHORING.

DESIGN PARAMETERS:						
WIND LOAD:	0.72 kPa	[15				
DAINLLOAD.	0.25 kDa	řг				


RAIN LOAD: 0.25 FPa [15.2 psf.]
SNOW LOAD: NONE
SEISMIC LOAD: NOT APPLICABLE

MATERIALS:
FRAME: ANODIZED ALUMINUM TUBING
ELECTROPLATED STEEL TUBING
FABRIC CLADDING: VINYL/POLYESTER FABRIC
FIRE RETARDANT RATING- ULC S-109,
NFPA 701, CALIFORNIA FIRE MARSHAL

AREA: 5600 sqft [520 sqm] WEIGHT: 4800 lbs [2177 kg]

	8' SIDEPOLES	10' SIDEPOLES	
Α	140' [42.67m]	140' [42.67m]	
В	40' [12.19m]	40' [12.19m]	
С	156' [47.55m]	160' [48.77m]	
D	56' [17.07m]	60' [18.29m]	
E	8' [2.43m]	10' [3.01m]	
F	8' [2.43m]	10' [3.01m]	
G	25' [7.62m]	27' [8.23m]	

SPECIAL Event SALES



				_	
CLIEN.	ALL DIMENSIONS IN INCHES				
OLILIY	DATE	DRAWN	DESCRIPTION	v	
	20/03/14	RB	ISSUED FOR CONST.	0	
DESC					
			CONSULTANT: ALSTRAN CORP, PEGA PERMIT P10591		
	SI7F	SHEET	ALE 1:250		
DRAW		В			

POLE TENT - 40X140

SIZE						
	DRAWN	DATE	EST. WEIGHT (#)			
	ND	28/03/14	, ,			
ENITAL ED OR Y ANY	CHECKED	DRAWING NUMBER			REV	
Y ANY ENT OF 4			PT-40140		0	