



ITEM NO.	QTY.	PART NO.	DESCRIPTION	WEIGHT [ea.]
1	2	588-5020	TOP END 60' x 20'	310 [141]
2	6	588-5030	TOP MID, 60' x 20'	290 [132]
3	7	588-5040	CENTERPOLE	115 [52.2]
4	40	588-5060	SIDE POLE	12 [5.4]
5	40	588-5061	CROWN & NUT	2 [1]
6	48	588-5080	STAKE BAR	6 [2.8]
7	96	589-1401	STAKE, 1" x 42"	9 [4.1]
8	54	589-1403	STAKE, 3/4" x 36"	7 [3.2]
9	48	588-5080	GUY ASSEMBLY	2 [1]
10	7	588-5050	FLAG POLE	3 [1.4]
11	7	588-5051	FLAG	3 [1.4]
12	20	589-0620	WALL FR WINDOW, 8' x 20'	40 [18.1]

ANCHORING:
 - ALL SIDE POLE LOCATIONS ANCHORED WITH A SINGLE GUY STRAP AND 2- 1"x42" PINS.
 - ALL SIDE POLES SHALL BE ANCHORED WITH 1- 3/4"x36" PIN
 - ALL CENTER POLES SHALL BE ANCHORED WITH 2 - 3/4"x36" PIN
 - ALL CORNERS SHALL BE ANCHORED WITH 3 GUY STRAPS, 45° APART. EACH GUY STRAP SHALL HAVE 2- 1"x42" PINS
 - EACH GUY LOCATION SHALL HAVE A RESTRAINT CAPACITY OF 13.5KN [3,000 lbf] TO WITHSTAND A 100kph [62 Mph] WIND
 - EACH 1"x42" PIN SHALL REQUIRE A PULLOUT FORCE OF 13.5KN [3,000 lbf]
 - EACH 3/4"x36" PIN SHALL REQUIRE A PULLOUT FORCE OF 9KN [2,000 lbf]

*INSTALLATION CREW MUST ENSURE THAT EACH STRUCTURE/INSTALLATION IS PROPERLY SECURED. SITE CONDITIONS MAY REQUIRE ALTERNATE ANCHORING METHODS OR ADDITIONAL ANCHORING.

DESIGN PARAMETERS:
 WIND LOAD: 0.72 kPa [15 psf.]
 RAIN LOAD: 0.25 kPa [5.2 psf.]
 SNOW LOAD: NONE
 SEISMIC LOAD: NOT APPLICABLE

MATERIALS:
 FRAME: ANODIZED ALUMINUM TUBING
 ELECTROPLATED STEEL TUBING
 FABRIC CLADDING: VINYL/POLYESTER FABRIC
 FIRE RETARDANT RATING- ULC S-109,
 NFPA 701, CALIFORNIA FIRE MARSHAL

AREA: 6400 sqft [595 sqm]
 WEIGHT: 5393 lbs [2446 kg]

	8' SIDEPOLES	10' SIDEPOLES
A	160' [48.77m]	160' [48.77m]
B	40' [12.19m]	40' [12.19m]
C	176' [53.64m]	180' [54.86m]
D	56' [17.07m]	60' [18.29m]
E	8' [2.43m]	10' [3.01m]
F	8' [2.43m]	10' [3.01m]
G	25' [7.62m]	27' [8.23m]



PROFESSIONAL ENGINEER ALBERTA
 28-MAR-2014

ALL DIMENSIONS IN INCHES				CLIENT
REV	DESCRIPTION	DRAWN	DATE	DESCRIPTION
CONSULTANT: ALSTRAN CORP APEGA PERMIT P10591				POLE TENT - 40X160 DRAWN ND DATE 28/03/14 EST. WEIGHT (#)
SCALE	SHEET SIZE	CHECKED	DRAWING NUMBER	
1:300	B		PT-40160	REV 0

NOTICE: THIS DOCUMENT CONTAINS CONFIDENTIAL INFORMATION AND SHALL NOT BE REPRODUCED OR DISCLOSED IN WHOLE OR IN PART FOR USE BY ANY OTHER PARTY WITHOUT PRIOR WRITTEN CONSENT OF SPECIAL EVENT SALES. COPYRIGHT 2014